



Brunswick / Glynn County Joint Water & Sewer Commission

Oct. 2017

WWTF Capacity Rating

	Weekly Limit		Monthly Limit		Current Average		% OF CAPACITY
ACADEMY CREEK WWTF	16.9	MGD	13.5	MGD	8.22	MGD	60.89% <i>*1 (I & I PROBLEM)</i>
DUNBAR CREEK WWTF	5	MGD	4	MGD	3.204	MGD	80.10% <i>*2 (I & I PROBLEM)</i>
SOUTH PORT WWTF	1.875	MGD	1.5	MGD	0.413	MGD	27.53%

*NOTE *1: Academy Creek WWTF has an I & I Problem, which if fixed would reduce the amount of treated waste!
There are several projects under way to repair the system and reduce the I & I Problem.*

*NOTE *2: Dunbar Creek WWTF has an "EXTREME" I & I Problem, which if fixed would reduce the amount of treated waste!
There are several projects under way to repair the system and reduce the I & I Problem.*