

WATER PROVIDED BY THE BGJWSC CONTINUES TO MEET OR EXCEED GEORGIA EPD AND USEPA STANDARDS.

**Water Quality Report | For Service Provided From January, 2015 to December, 2015 Issued May, 2016**



Substance (Units)	Goal	Max Allowed (MCL)	Year tested	Amount Detected by System(d)				Is it safe?	Source of Substance
				BWK PW# 1270000	NM PW# 1270142	SM PW# 1270150	SSI PW# 1270001		

**INORGANIC CONTAMINANTS**

Total Haloacetic Acids (ppb)	0	60	2015	0-5.26	0-5.09	0-4.66	0-3.7	Yes	By-product of drinking water chlorination
Total	0	80	2015	0-14	0-8.63	1.1-9.52	5.9-38.4	Yes	
Fluoride (a) (ppm)	4	4	2015	.42-.92	.51-1.08	.51-.94	.46-.96	Yes	Naturally occurring
Lead (2013)(b) (ppb)	0	AL=15	2013	0 - 2.5 tested 2013	0 - 8.3 tested 2013	0 tested 2013	0 - 2.5 tested 2013	Yes	Corrosion of household plumbing systems
Copper (2013) (b) (ppb)			2013	0 - 85 tested 2013	0 - 140 tested 2013	87 - 520 tested 2013	0 - 140 tested 2013	Yes	
Chlorine Residual (ug/L) (ppm)	0.2-4.0	4.0	2015	0.14-1.9	0.2-2.12	0.2-2.08	0.48-8.80	Yes	Added for disinfection and odor control
Phosphate (ppm)	.75	28.0	2015	.26-1.55	.25-.90	N/A	.14-1.21	Yes	
Alpha Emitters (2006) (pCi/l)	0	15	2006	< 2 tested 2006	3 tested 2006	4 tested 2006	3 tested 2006	Yes	Erosion of natural deposits expressed as PicoCuries per liter

**UNREGULATED SUBSTANCES**

Chloride (c) (ppm)	250	N/A	2015	25-160	25-40	20-30	25-35	Yes	Naturally occurring from lower water bearing zones
Hardness (as CaCO) (ppm)	N/A	N/A	2012	210 tested 2012	185 tested 2012	210 tested 2012	190 tested 2012	Yes	
pH			2015	6.90-8.11	6.2-8.43	6.00-8.10	6.5-8.90 4/26/2016	Yes	

**You can help conserve water. Call 1-866-987-7367 for tips and information.**

**Report available online at: [www.bgjwsc.org/about-the-bgjwsc/waterqualityreport](http://www.bgjwsc.org/about-the-bgjwsc/waterqualityreport) or call 912-261-7100 for a printed copy.**