



## Brunswick-Glynn County Joint Water and Sewer Commission

700 Gloucester Street, Suite 300, Brunswick, GA 31520

Phone: (912) 261-7110 Fax: (912) 261-7178

[www.bgjwsc.org](http://www.bgjwsc.org)

The Brunswick Glynn Joint Water & Sewer Commission NPDES Permit GA0025313 in accordance with aforesaid permit and DNR Regulation 391-3-6-05 Emergency Actions, hereby make Public Notification of a wastewater spill that was reported on Friday March 27, 2015 from a ruptured private sanitary sewer service line.

**Date of Spill:** 03/27/2015

**Location of Spill:** Fairview Trailer Park, Holly Ave. / Robarts Rd  
Brunswick, Georgia 31525

**Cause of Spill:** Ruptured private sanitary sewer service lateral

**Estimated volume  
Of discharge:** Approximately 2,500 Gallons

**State Waters Discharged:** Turtle River Basin

**Corrective Action Taken:** Upon notification JWSC responded immediately and repaired the private sanitary sewer service lateral. JWSC then Notified EPD and local authorities & the Glynn County Health Department District Environmental Health Manager.

This Notice is being sent to the Brunswick News and the Radio Station 102.5 Quantum Communications. Via Facsimile for publication and airing

For any additional information contact Kirk Young, Superintendent of Systems Pumping and Maintenance Division, Brunswick-Glynn County Joint Water and Sewer Commission : Phone Number 912-261-7152