

## CLARIFICATION NO. 1 to

Specifications and Contract Documents
for
URBANA SANITARY SEWER IMPROVEMENTS
for
Brunswick-Glynn County JWSC

Project No. 319

Clarification Date: 7/8/2015

## Item No. 1:

Urbana Sanitary Sewer Improvements Specifications
Section 01110 Measurement and Payment, Bid Item No. 5 – Sewer Service
Connections: Sewer Service Connections and Sewer Service Transfer Piping
are specified as PVC SOR 26. Should read as PVC SDR 26.

## Item No. 2:

Urbana Sanitary Sewer Improvements Specifications Section 00410 Bid Form, Items No. 5 B, C and F- Sewer Service Connections: Should read as PVC SDR 26

**END CLARIFICATION NO. 1** 

Name. Title

Date