



RFI RESPONSE NO. 1  
to  
Specifications and Contract Documents  
for  
URBANA SANITARY SEWER IMPROVEMENTS  
for  
Brunswick-Glynn County JWSC

Project No. 319

RFI Response Date: 7/2/2015

**RFI Question No. 1:** Will Limestone be permissible to use in Pipe Laying, if conditions permit, or in Base for Roadway?

**Response No. 1:** Limestone is acceptable for roadway base (GABC Type I) and pipe bedding.

END RFI RESPONSE NO. 1

\_\_\_\_\_  
Name, Title

\_\_\_\_\_  
Date