

QUESTIONS AND ANSWERS LIFTSTATION 2030

1. Can fuseable pvc be used instead of HDPE on the directional drills? **NO**
2. What date do you for see the notice to proceed to be given? **30 DAYS AFTER COMMISSION APPROVAL**
3. Is there an estimate for the job? **NO**