



Brunswick-Glynn County Joint Water and Sewer Commission

700 Gloucester Street, Suite 300, Brunswick, GA 31520

Phone: (912) 261-7110 Fax: (912) 261-7178

www.bgjwsc.org

The Brunswick Glynn Joint Water & Sewer Commission NPDES Permit GA0025313 in accordance with aforesaid permit and DNR Regulation 391-3-6-05 Emergency Actions, hereby make Public Notification of a wastewater spill that was reported on Thursday April 09, 2015 from a broken main service line.

Date of Spill: 04/09/2015

Location of Spill: Hospice of the Golden Isles at the intersection of Glyngo Parkway & Hibbard Lane.
Brunswick, Georgia 31525

Cause of Spill: This spill appears to be caused by an unidentified source who accidentally ruptured a sewer main during the process of cleaning the roadside ditch. The JWSC responded within 30 minutes of the notification with Vac-Con trucks and collected 600 gallons of the release sewage and repaired the broken sewer main with JWSC crews.

Estimated volume

Of discharge: Approximately 700 Gallons

State Waters Discharged: Ditch leading to Yellow Bluff Creek

Corrective Action Taken: JWSC repaired the broken sewer main and cleaned up the area and disinfected with lime. The JWSC placed notification signs along the ditches and adjacent roadways. The JWSC Laboratory testing is ongoing. The EPD was notified, local authorities and the Glynn County Health Department District Environmental Health Manager

This Notice is being sent to the Brunswick News and Radio Station 102.5 Quantum Communications. Via Facsimile for publication and airing

For any additional information contact Kirk Young, Superintendent of Systems Pumping and Maintenance Division, Brunswick-Glynn County Joint Water and Sewer Commission : Phone Number 912-261-7152