



Brunswick-Glynn County Joint Water and Sewer Commission

700 Gloucester Street, Suite 300, Brunswick, GA 31520

Phone: (912) 261-7110 Fax: (912) 261-7178

www.bgjwsc.org

The Brunswick Glynn County Joint Water & Sewer Commission NPDES Permit GA0038938 in accordance with aforesaid permit and DNR Regulation 391-3-6-05 Emergency Actions, hereby make a Public Notification of a Sanitary Wastewater spill that was reported on Monday June 29th, 2015.

Date of Spill: 06/29/2015

Location of Spill:

Blue Beacon Truck Wash (Private System on Private Property)
2752 US-17,
Brunswick, GA 31523

Cause of Spill:

This spill was caused by debris buildup within the collection line. The receiving manhole lid was found open and both ring and cover were displaced. The debris removed from the clogged line were trash, large pieces of asphalt, and car parts. The discharge of the spill was estimated at 1,200 Gallons.

State Waters Discharged: The wastewater entered a storm water catch basin which led to a ditch line which leads to a tributary of Fancy Bluff Creek.

Corrective Action Taken: JWSC was notified and immediately responded to the report with a Vac-Con crew and evaluation team, which removed the debris and trash from the manhole. Normal flow was established after being cleaned. The JWSC responded quickly and normal flow was established within 15 min. This spill was caused by a problem on a private collection system line owned by Blue Beacon Truck Wash. The storm water collection system was cleaned and the ditch line was cleaned and treated with lime and posted.

The EPD and local authorities & the Glynn County Health Department District Environmental Health Manager were notified of the incident.

This Notice is being sent to the Brunswick News and the Quantum Communications radio station. Via Facsimile for publication as a public service announcement. For any additional information contact Kirk Young Superintendent of Pump and Maintenance Operations in Glynn County: Phone Number 912-261-7152.