



**Brunswick – Glynn  
Joint Water & Sewer Commission**

February 4, 2016

**PROJECT :** CANAL ROAD WATER & SEWER FORCE MAIN

**IMPROVEMENTS – PROJECT NO. 419**

**ADDENDUM:** One (1)

Canal Road Water & Sewer Force Main Improvements is hereby amended as follows:

**1) An updated map has been posted to the BGJWSC site. The location is:**

[http://www.bgjwsc.org/wp-content/uploads/2016/01/Canal\\_Road\\_Water\\_Sewer\\_Improvements-Revised\\_Exhibit\\_Map.pdf](http://www.bgjwsc.org/wp-content/uploads/2016/01/Canal_Road_Water_Sewer_Improvements-Revised_Exhibit_Map.pdf)

Please review and utilize the updated map from now onwards.

**2) Clarification on consideration of HDPE pipe use:**

- Water Main – 20” HDPE C906, DR9 with a 24” casing (where applicable) would be required if used in place of the specified 16” PVC 235 DR18.
- Sewer Main – 24” HDPE with HDPE C906, DR11, PE 3408 with a 26” casing (where applicable) would be required if used in place of the specified 20” PVC 235 DR18.

**3) Question regarding 20’ box leading into 8” pipe**

Plans have been revised to show the equalization box removed and the 20” force main terminating into a new manhole on Ogden Drive. See revised plan sheet 10.

[http://www.bgjwsc.org/wp-content/uploads/2016/01/Canal\\_Road\\_Water\\_Sewer\\_Improvements\\_Revisions\\_2-3-16.pdf](http://www.bgjwsc.org/wp-content/uploads/2016/01/Canal_Road_Water_Sewer_Improvements_Revisions_2-3-16.pdf)

**4) Traffic control**

The contractor is responsible for submittal plans and approvals from Georgia Department of Transportation and Glynn County.



**5) Can you provide the restraint distances for the 20” Forcemain?**

See revised plan detail sheet 14. The restraint distances are provided at the bottom of the chart.

**6) How will pay requests be handled?**

The prices according to the Bid Proposal will be used as the schedule of pay items for this contract. The Contractor shall prepare a Schedule of Values for the major portions of this project and submit to the Owner and Engineer for review and approval prior to the first draw request.

Pay Request format should provide columns showing:

- Work Completed this Period
- Work Completed to Date (percentage and \$ value)
- Contract Amount
- Balance to Finish
- Updated Construction Schedule specifying and revisions to original schedule
- Material stored will be included and will be verified by BGJWSC inspection team

Cut-off Date – 25<sup>th</sup> of every month.

Submittal Procedures – submit pay requests to Elizabeth Burns (BGJWSC Planning & Construction Administrative Assistant) for review and recommendation for payment to the Owner. Standard AIA Partial Pay Request format, or other approved format, may be used for pay requests.

**7) Does the proposer/contractor have the ability to use directional drilling/bore methods or fusible piping in areas shown as open cut?**

Yes, the contractor may use directional boring methods in other areas that are not specifically requiring directional drilling. However the proposer will need to show these proposed locations redlined on a set of the bid plans for the BGJWSC and Engineer of Record to review and approve.



**8) Can you provide the contract and contact information for Atlanta Gas Light?**

A contract example and cost for the gas line relocation is on the BGJWSC website with a link provided below.

[http://www.bgjwsc.org/wp-content/uploads/2016/01/Canal\\_Road\\_Relocation\\_Map-AGL\\_Resources.pdf](http://www.bgjwsc.org/wp-content/uploads/2016/01/Canal_Road_Relocation_Map-AGL_Resources.pdf)

[http://www.bgjwsc.org/wp-content/uploads/2016/01/Relocation\\_AGLC\\_-\\_Contract\\_Canal\\_Rd.pdf](http://www.bgjwsc.org/wp-content/uploads/2016/01/Relocation_AGLC_-_Contract_Canal_Rd.pdf)

Mr. Jacob Ziliak  
AGL Resources  
10 Peachtree Place– 11<sup>th</sup> Floor  
P.O. Box 4569  
Atlanta, GA 30302-4569  
(404) 584-4000

Any utility relocation agreement will be between the Contractor and Utility Company. BGJWSC will not be a party to these agreements.

**All applicants under this Invitation To Bid are kindly requested to acknowledge receipt of this Addendum in original only.**



**ACKNOWLEDGEMENT  
ADDENDUM NUMBER ONE**

**(1)**

**CANAL ROAD WATER & SEWER FORCE MAIN IMPROVEMENTS – PROJECT NO. 419**

**Date:** \_\_\_\_\_

The above Addendum is hereby acknowledged:

---

(NAME OF BIDDER)

---

Signature

---

Title