



## **Brunswick – Glynn County Joint Water & Sewer Commission**

February 27, 2018

**PROJECT: IFB – CCTV Camera Inspection  
2016 SPLOST N Mainland Phase II and Phase III Downstream  
Assessment**

**ADDENDUM: One (1)**

**DUE DATE: Tuesday, March 13, 2018 - NOON**

### **THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES OR CLARIFICATIONS:**

- 1) Is it correct that no bypass is required since a float is being utilized?**
  - **The decision to bypass will be left up to the contractor. If TV images produce adequate footage, a bypass will not be required. If adequate TV images cannot be produced on the first run through, it is up to the contractor to obtain better images.**
  
- 2) Is this for CCTV only with no laser?**
  - **The basic IFB is for CCTV only, but the contractor is welcome to include laser as an optional/alternative item on the updated Bid Form. Please see Bid Form Item 2A for clarification.**

- 3) **Is video required or is this for manhole inspection only?**
- **The basic IFB is for Manhole inspection only, however the contractor is welcome to include video as an option or alternative on the updated Bid Form. Please see Bid Form Item 4A for clarification.**
- 4) **Please note that Line Item 5 “Trunk Manhole”, from the original Bid Form has been replaced with “Traffic Control”.**
- 5) **Is traffic control to be added into per foot price or added as an additional bid item?**
- **As referenced in the IFB, all items pertaining to traffic control, permitting, jetter trucks, etc. are the sole responsibility of the contractor. Please see updated Bid Form Item 5 for clarification.**
- 6) **Is there the option for night work hours?**
- **Yes. Due to heavy traffic at peak times during the day at the intersection of Old Jesup Road and Community Road, night work will be allowed providing all permits have been obtained from the Glynn County.**
- 7) **Glynn County Traffic Control and Permitting requests should be sent to Chuck Flowers, Glynn County at [cflower@glynncounty-ga.gov](mailto:cflower@glynncounty-ga.gov)**
- 8) **What is the protocol in the event a pipe collapses during televising and there is no bypass?**
- **Please refer to attachment, Emergency Procedure in Event of Line Failure**

## REVISED - BID FORM - Payment Item Schedule

Item	Description	Unit	Unit Cost	Ext Cost
1	Mobilization for Project Work (lump sum)	1		
2	CCTV only, No Cleaning - up to 30" diameter (linear feet)	6,000		
3	Flow Bypassing - up to 30" diameter (lump sum)	1		
4	Manhole Inspection – Report Only (each)	19		
5	Traffic Control (lump sum)	1		

### Alternate Bid Items:

Item	Description	Unit	Unit Cost	Ext Cost
2a	CCTV – Laser Option (linear feet)	6,000		
4a	Manhole Inspection – Video Option (each)	19		

**To be considered responsive, bidders are required to bid on all work items listed on the Bid Form – Pay Item Schedule.**

Submitted by: \_\_\_\_\_

\_\_\_\_\_  
(NAME OF BIDDER)

By: \_\_\_\_\_  
(SIGNATURE)

\_\_\_\_\_  
(TITLE)

\_\_\_\_\_  
(DATE)

\_\_\_\_\_  
(SEAL) (ATTEST)

\_\_\_\_\_  
(ADDRESS)

\_\_\_\_\_  
(PHONE NUMBER)

\_\_\_\_\_  
(FAX NUMBER)

\_\_\_\_\_  
(LICENSE NUMBER) (If applicable)

\_\_\_\_\_  
(E-MAIL ADDRESS)

Submitted by: \_\_\_\_\_  
(NAME OF BIDDER)



All applicants under this Request For Qualifications are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT**  
**ADDENDUM: One (1)**

**Date:** \_\_\_\_\_

The above Addendum is hereby acknowledged:

\_\_\_\_\_  
(NAME OF BIDDER)

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Title