



## **BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION**

February 1, 2019

**PROJECT: IFB – South Harrington Water Production Facility Service  
Pump Replacement and Installation Solicitation No. 19-005**

**ADDENDUM: Two (2)**

**DUE DATE: TUESDAY, FEBRUARY 12, 2019 12:00PM, NOON**

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING  
QUESTIONS:**

- 1) QUESTION: The existing Peerless Pump based on the serial number provided is rated at 1,100 GPM at 116' Head. Is it the intention of the BGJWSC to source a pump with a lower flow rate?**

**ANSWER: 116' Head is correct. We would like to duplicate the pump for the provided serial number at 50HP.**



**All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.**

**ACKNOWLEDGEMENT  
ADDENDUM: TWO (12)**

**DATE:** \_\_\_\_\_

**The above Addendum is hereby acknowledged:**

\_\_\_\_\_  
**(NAME OF BIDDER)**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Title**