



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

February 12, 2019

PROJECT: RFP – Smoke and Dye Testing for SSI District Project No 807
for the BGJWSC Solicitation No. 18-010

ADDENDUM: One (1)

DUE DATE: WEDNESDAY, FEBRUARY 20, 2019 12:00PM, NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING
QUESTIONS:**

- 1) QUESTION:** The proposal has called for fifteen (15) dyed water testing. However, the addendum provided in the RFP described groundwater flow monitoring. Can you provide additional information on the type of deliverables that the Brunswick Glynn-County Joint Water and Sewer Commission is expecting for dyed water portion of this project (both for dyed water tracing and dye water flooding)?

ANSWER: See Page 7 of 20 for section titled “Storm Water Inflow Abatement Design”. A technical memorandum should be issued detailing results of dye water tracing and flooding program and including outline recommendations to eliminate deficient piping and cross-connection(s).

- 2) QUESTION:** For scheduling purposes, how much time should be allotted between the initial inspections and the smoke tests for the BGJWSC to repair any damaged points in the sewer system? Additionally, should re-inspections of the systems after the smoke tests, assuming the tests find points of repair, be included in the total anticipated not-to-exceed cost?

ANSWER: JWSC will make repairs as budget allows. Private property owners will be allotted time to make repairs to private issues. The selected firm will not be responsible for follow-up smoke testing or flow monitoring. These costs should not be included in proposal.

3) QUESTION: On page 9, Section 6.0 Evaluation Criteria, is an engineering license mandatory for this project?

ANSWER: As one of the deliverables for the project is recommended actions for I&I abatement, engineering licensure is required.

4) QUESTION: Will water be provided at no cost for the Dye water testing?

ANSWER: Water will be provided at no cost. A hydrant meter will be provided for water use accounting.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title