



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

March 12, 2019

PROJECT: RFP No. 19-015 – Engineering Services Odor Control Study for Academy Creek Water Pollution Control Facility for the BGJWSC

ADDENDUM: One (1)

DUE DATE: FRIDAY, MARCH 29, 2019, 12PM NOON, EST

THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING QUESTIONS:

1) QUESTION: Page One (1) of the RFP requires the submission of a Price Proposal. Page Two (2) states that the document is a Qualifications based procurement of Professional Engineering services. Is JWSC requiring pricing?

ANSWER: Yes, JWSC has made the decision to include price as a factor in the evaluation of this RFP

2) QUESTION: We understand that there was an Odor Control Study conducted at the WPCF in Summer/Fall of 2018. Would the JWSC make this study available?

ANSWER: Yes, a trial was completed utilizing a magnesium hydroxide-lime slurry addition at three (3) upstream pump stations. The data from this trial will be made available to the selected firm.

3) QUESTION: Will there be a pre-proposal meeting required for this project?

ANSWER: No, a pre-proposal meeting has not been scheduled for this solicitation. Any questions regarding this RFP may be presented to Pamela Crosby, BGJWSC Director of Procurement, via email (pcrosby@bgjwsc.org), no later than 5:00PM March 15, 2019.

4) QUESTION: Are there any odor control measures currently being implemented at Academy Creek, and if so what are the types and locations of the measures being employed?

ANSWER: There is currently a chemical mist being sprayed around the influent wet well that assists with odor masking



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title