

BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

September 16, 2019

PROJECT: **Invitation for Bid-Mallery Street Water Production Facility**

Service Pump & Installation, Solicitation No. 20-012

One (1) ADDENDUM:

DUE DATE: TUESDAY, OCTOBER 8, 2019 12:00PM, NOON

THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING QUESTIONS:

1) QUESTION: Please provide the duty point for the pump, Flow Rate and Head

ANSWER: The Flow Rate is 750-800 GPM and the Head is 115ft.

2) QUESTION: Will other brand pumps be accepted, as equal, thru the preapproval process for the split case for this project?

ANSWER: Only Peerless pumps will be accepted. BGJWSC is in the process of standardizing to the Peerless Model.

3) QUESTION: Will site visits be available prior to submission of the solicitations?

ANSWER: Yes, site visits are available. Please contact Water Production Superintendent, Donnie Bankston at 912-717-3242 to schedule a visit

4) QUESTION: Will this project require a contractor's license issued by the state of GA?

ANSWER: The contractor will be required to possess a current and up to date contractor's license issued by the state of GA.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

ACKNOWLEDGEMENT ADDENDUM: ONE (1)

	DATE:	
The above Addendum is here	eby acknowledged:	
	(NAME OF BIDDER)	
Signature	Title	