



**NOTES:**

1. JWSC TO INSTALL METER AND METER BOX. METER IS TO BE PURCHASED THROUGH JWSC.
2. ALL FITTINGS IN LATERAL SHALL BE COMPRESSION TYPE.
3. A MINIMUM OF TWO FULL THREADS ARE REQUIRED FOR TAPPING SLEEVE TO GO INTO THE PIPE WALL.
4. INSULATED SINGLE STAND COPPER WIRE SHALL BE STRAPPED TO THE PIPE AND ATTACHED TO THE CORPORATION AND CURB STOPS.
5. INSTALL PVC PLUG IN ALL CURB STOPS IF WATER SERVICE IS "NOT IN USE" (NO METER IS INSTALLED).
6. WATER SERVICES SERVING VACANT LOTS (SERVICE NOT IN USE), SHALL INCLUDE A "W" CUT INTO THE CURB. FOR NEW DEVELOPMENT AREAS WHERE THE WATER SERVICE IS "NOT IN USE", A #4 REBAR STAKE PAINTED BLUE. BLUE STAKE SHALL BE VISIBLE WITH 4" TO 6" ABOVE GRADE.
7. POLYETHYLENE WATER SERVICE LINE SHALL BE PERPENDICULAR TO THE MAIN UNLESS APPROVED OTHERWISE BY BGJWSC.

NOT TO SCALE



**BRUNSWICK-GLYNN COUNTY  
JOINT WATER & SEWER  
COMMISSION**

1703 Gloucester Street Phone: (912) 261-7110  
Brunswick, Georgia 31520 Fax: (912) 261-7178  
Website: www.bgjwsc.org

**SINGLE WATER SERVICE DETAIL**

**JWSC STANDARD DETAIL 2-16**

Date: JUNE 2018