



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

January 27, 2020

PROJECT: Invitation for Bid No. 20-007 – PUMP STATION 4021
REHABILITATION & UPGRADE

ADDENDUM: One (1)

DUE DATE: Tuesday, February 25, 2020 12:00PM, NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING
QUESTIONS:**

1) QUESTION: Will the equipment in Section 11210 be pre-purchased by JWSC or will it be included in the contractors bid package

ANSWER: No, JWSC will not pre-purchase the materials mentioned in Section 11210. The contractor should provide pricing for those items in their bid package.

2) QUESTION: Can pumps manufactured by WILO USA be added as an approved equal in the specification?

ANSWER: No, please submit your bid using the KSB pumps specified in the RFP documents and technical specs.

3) QUESTION: To clarify the scope of work, will a new Variable Frequency Drive need to be provided or is it Electrical Contracting work to set up the drive along with SCADA?

ANSWER: As per the 4021 project sheets, the work to be performed under this contract consists of furnishing all labor, materials, tools, equipment, and incidentals required to construct complete in place and ready to operate a new Wastewater Pumping Station and associated force main. More specifically, the work includes, but is not limited to:

- Security fencing and related site work
- Erosion and sedimentation controls
- New pre-cast concrete wet well top with aluminum access covers
- New pre-cast valve pit
- New electrical shed and equipment
- Pumping equipment and accessories
- Electrical work including controls and SCADA
- Discharge piping, valves, effluent flow meter, etc
- Eighteen (18) inch HDPE force main with associated fittings and appurtenances

**The control work as per 4021 rehabilitation upgrade full set is as follows:
Electrical Controls shall be controlled by JWSC's standard SCADA Pump Controller as manufactured by Electric Machine Control, Inc. (205) 661-3998, Trussville, AL.**



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title