



## **BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION**

February 5, 2020

**PROJECT:** Invitation for Bid No. 20-007 – PUMP STATION 4021  
REHABILITATION & UPGRADE

**ADDENDUM:** Three (3)

**DUE DATE:** Tuesday, February 25, 2020 12:00PM, NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING  
QUESTIONS:**

**\*\*Please be aware that the product specifications provided on page 139 of the IFB documents for INDURON are out of date. Please refer to the table below for current INDURON product offerings and/or approved equal based on manufacturer recommendations. This table will also be posted to the solicitation website, <https://www.bgjwsc.org/invitation-to-bid-no-20-007-pump-station-4021-rehabilitation-and-upgrade-project-for-the-bgjwsc/> \*\***

**Material Schedules**

**SYSTEM: 247**

**TYPE: POLYURETHANE**

**USE: EXTERIOR FERROUS METALS**

**SURFACE PREPARATION: SP-6**

| <b>Coat</b> | <b>Minimum Dry Film Thickness (Mills)</b> | <b>Ameron</b>       | <b>Carboline</b>  | <b>Induron</b>                     | <b>Sherwin Williams</b> | <b>Tnemec</b>                      | <b>INDURON</b>                         |
|-------------|---|---------------------|-------------------|------------------------------------|-------------------------|------------------------------------|--|
| 1st         | 3.0                                       | Amercoat 370 or 385 | Carboguard 893 SG | <del>Amourguard P-14 Primer</del>  | Macroproxy 646 FC Epoxy | Series 66-1211 Epoxoline           | <b>CERAMAPRIME</b>                     |
| 2nd         | 4.0-6.0                                   | Amercoat 370 or 385 | Carboguard 893 SG | <del>Amourguard Epoxy</del>        | Macroproxy 646 FC Epoxy | Series 66-Color Epoxoline          | <b>PERMA-CLEAN II SEMI GLOSS EPOXY</b> |
| 3rd         | 2.0-3.0                                   | Amercoat 450 Series | Carbothane 134 HG | <del>Indurethane 5500 Enamel</del> | Sherthane 2K Urethane   | Series 1074-Color Endura-Shield IV | <b>INDURATHANE 6600 PLUS</b>           |



**All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.**

**ACKNOWLEDGEMENT  
ADDENDUM: THREE (3)**

**DATE:** \_\_\_\_\_

**The above Addendum is hereby acknowledged:**

\_\_\_\_\_  
**(NAME OF BIDDER)**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Title**