



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

May 12, 2020

PROJECT: Invitation for Bid No. 20-014 – Lift Station 4003 Upgrades

ADDENDUM: One (1)

DUE DATE: TUESDAY, June 2, 2020 12:00PM, NOON

THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING QUESTIONS:

- 1) **QUESTION:** Who is responsible for the bypass pumping on this project? Will JWSC handle that in-house?

ANSWER: The CONTRACTOR will be responsible for providing all bypass pumping materials, equipment, and labor for the project.

- 2) **QUESTION:** Please clarify the type of concrete required. 5000psi concrete specs conflicts with the 4000psi on Concrete Notes, #3 on SLR.

ANSWER: Section 03301 Cast-In-Place Concrete Paragraph 2.12 A 1 has been updated to:

- Minimum Compressive Strength: 4000 psi at 28 days

- 3) **QUESTION:** Is there a trolley hoist specification?

ANSWER: The trolley hoist shall be a low headroom, hand operated chain trolley hoist with 5-ton rated capacity. The trolley hoist shall be as manufactured by Harrington, model NTH Navy Trolley Hoist, or approved equal by the JWSC and Engineer.

- 4) **QUESTION:** Is BIOAIR an approved odor control supplier for this project?

ANSWER: BIOAIR, Voorhees, NJ, is approved as a supplier of the odor control system for this project. The Base Bid item for the Odor Control System in the Bid Form shall include BIOREM system. The Alternate Bid item for the Odor Control System, replacing the Base Bid item for the Odor Control System, shall include the BIOAIR system. Both items shall include all materials, equipment, labor, and startup services for a complete and operational odor control system. BGJWSC reserves the right to select any combination of Base Bid and Alternates in determining the successful bid.

**** Please note the following:**

- **In Section 03301, page 347 of the RFP documents, the psi has been updated to 4000psi at 28 days.**
- **In Section 15710, page 470 of the RFP documents, BIOAIR has been added as an approved manufacturer of the biotrickling filter equipment.**
- **In Section 15710, page 473 of the RFP documents, the Fan should have a Class 1, Division 2 compliant motor suitable for hazardous area operation.**
- **In Section 15710, Page 474 of the RFP documents, 2.03H i a has been updated to: “NEMA 4X 316 stainless steel enclosure with pedestal legs”.**
- **In the PLANS, Sheet 2.1 has been replaced with “Sheet 2.1 noted with Addendum 1 – May 12, 2020”**
- **In the RFP, the original Bid Form has been updated. Please submit your bids with Bid Form Updated May 12, 2020.**



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title