



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

June 21, 2021

PROJECT: INVITATION FOR BID NO. 21-024 PRIORITY BASIN CLEAN--
CCTV

ADDENDUM: One (1)

DUE DATE: Tuesday, June 29, 2021 – 12:00 P.M., NOON EST

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING
QUESTIONS:**

1) **QUESTION:** Will the County be responsible for locating and uncovering buried manholes?

ANSWER: The JWSC can assist in locating and uncovering buried manholes, however the Contractor should allow for 3-5 days for the JWSC to do so.

2) **QUESTION:** In the bid form it says “furnishing all labor, materials, and equipment necessary to install approximately 2,900 linear feet of 8-inch HDPE force main...”. Will that be necessary for this bid?

ANSWER: No, that is not a requirement of this project. The Bid documents have been amended to reflect this, and the scope of work should read as follows:

- **The purpose of this bid is to obtain competitive unit prices for all labor, material, and equipment necessary to clean existing and inspect via closed circuit television (CCTV) existing sanitary sewers ranging in size from 8- to 18-inch diameter. The work includes hydraulic root cutting and cleaning, grinding protruding break-in service connections, remote televising and recording of the sewer. All project locations will be within the Owner’s service area.**

3) QUESTION: Will the owner be responsible for set up and maintaining a sanitary dumping area and disposing of all debris dumped at 149 Indigo Drive?

ANSWER: 149 Indigo Drive has existing grit pads that are maintained by owner.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title