



**BRUNSWICK-GLYNN JOINT
WATER & SEWER COMMISSION**
August 24, 2021

PROJECT: Invitation for Bid No. 22-005 Sea Palms West CIPP

ADDENDUM: One (1)

DUE DATE: Thursday, September 9, 2021 – 12:00 P.M., NOON EST

THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING QUESTIONS:

- 1) **QUESTION:** Can the Owner identify any locations that are expected to require a point repair?

ANSWER: No expected locations where point repairs will be required. However, with potential heavy cleaning on ductile iron lines, Owner wishes to have a number for point repairs in the event they are necessary.

- 2) **QUESTION:** Can the Owner identify the details that are to be included in the “open cut point repair” bid item? For example: asphalt, concrete, sod, etc.

ANSWER: The majority of pipe sections are underneath either the roadway, driveways, or established landscaping. Pricing should include necessary steps to return location to existing or improved conditions.

- 3) **QUESTION:** Can the Owner provide a length that should be used to determine the unit cost for a point repair?

ANSWER: 20 feet

- 4) **QUESTION: Can the Owner please describe the length of pipe intended to be bid as “1 Segment” for Bid Items #13-16? Also, can bid items be added for each diameter for Bid Items #13-16?**

ANSWER: One segment is manhole to manhole, regardless of length. For estimating purposes, the average segment length is 187 lf. Owner declines to add additional bid items.

- 5) **QUESTION: What is the bid bond percentage for this project?**

ANSWER: The bid bond for this project is 5%.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title

BID FORM

DATE SUBMITTED: _____

PROJECT NAME: **Sea Palms West CIPP Rehabilitation**
Brunswick, Georgia

SUBMITTED TO: Brunswick – Glynn County Joint
Water and Sewer Commission
1703 Gloucester Street,
Brunswick, Georgia 31520

SUBMITTED BY:
Company Name: _____

Address: _____

Georgia Utility Contractor’s License No. _____

Acknowledge Receipt of Addenda Numbers _____

(Also include signed copies of each Addenda)

The undersigned as BIDDER hereby declares that the only person or persons interested in the BID as principal or Principals is or are named herein and that no other person than herein mentioned has any interest in the BID or in the Contract to be entered into; that this BID is made without connection with any other person or parties making a BID, and that it is in all respects fair and in good faith without collusion or fraud.

The BIDDER declares that he has examined the site of the work and informed himself fully in regard to all conditions pertaining to the place where the work is to be done; that he has examined the plans and specifications for the work and the documents relative thereto; and has read all General and Special Conditions furnished prior to the opening of bids; that he has satisfied himself relative to the work to be performed.

BID FORM (Continued)

UPDATED 08-24-2021

BID ITEMS: Sea Palms West Gravity Basin CIPP Rehab

Item	Description	Quantity	Units	Unit Price	Total
1	Mobilization	1	LS	\$ -	\$ -
2	Bypass Pumping	1	LS	\$ -	\$ -
3	Traffic Control	1	LS	\$ -	\$ -
4	Sanitary Sewer Mainline Pre-Cleaning Inspection ≤ 12" Diameter	6733	LF	\$ -	\$ -
5	Sanitary Sewer Mainline Cleaning ≤ 12" Diameter	6733	LF	\$ -	\$ -
6	Sanitary Sewer Mainline Post-Cleaning Inspection ≤ 12" Diameter	6733	LF	\$ -	\$ -
7	8" CIPP Mainline Rehabilitation	3751	LF	\$ -	\$ -
8	10" CIPP Mainline Rehabilitation	2197	LF	\$ -	\$ -
9	12" CIPP Mainline Rehabilitation	785	LF	\$ -	\$ -
13	Sanitary Sewer Mainline Heavy Sewer Cleaning ≤ 12" Diameter	1	SEGMENT	\$ -	\$ -
14	Sanitary Sewer Mainline Deposit Cut ≤ 12" Diameter	1	SEGMENT	\$ -	\$ -
15	Sanitary Sewer Mainline Root Cut Medium ≤ 12" Diameter	1	SEGMENT	\$ -	\$ -
16	Sanitary Sewer Mainline Root Cut Ball ≤ 12" Diameter	1	SEGMENT	\$ -	\$ -
17	Sanitary Sewer Mainline Lateral Cut ≤ 12" Diameter	1	EACH	\$ -	\$ -
18	Service Connection Reinstatement	15	EACH	\$ -	\$ -
19	Dye Testing of Existing Service Connections	15	EACH	\$ -	\$ -
20	Open Cut Point Repairs	1	EACH	\$ -	\$ -
21	Flowable Fill, Complete in Place	100	CY	\$ -	\$ -

TOTAL (Figures): \$ _____

(Words): _____

Bidders Name: _____

Signature: _____

Company Name: _____

Date: _____

The Bidder further agrees to accomplish all work and provide all material for the lump sum price submitted and understands that the lump sum price is subject to adjustment by either increase or decrease, only through a properly executed change order.

The Bidder further proposes and agrees to commence work under this contract, with adequate force and equipment, on a date to be specified in a written order of the Owner and shall fully complete all work hereunder within **one hundred fifty (150)** consecutive calendar days from and including said date.

The undersigned further agrees that, in case of failure on his part to execute the said Contract and Bonds within fifteen (15) consecutive calendar days after receipt of the conformed Contract Documents, the check or bid bond accompanying this Bid and the monies payable thereto, shall be paid into the funds of the Owner as liquidated damages for such failure otherwise, the check or Bid Bond accompanying this Bid shall be returned to the undersigned.

I understand that collusive bidding is a violation of state and federal law and can result in fines, prison sentences, and civil damage awards. I agree to abide by all conditions of this Invitation for Bids and certify that I am authorized to sign this Bid for the Bidder.

This the _____ day of _____ 2021.

Company Name: (Please Type or Print)

Person Authorized to Sign:

Name: _____

Name: _____

Street: _____

Signature: _____

City: _____

Title: _____

State: _____ Zip: _____

Telephone Number: () _____

Fax Number: () _____

E-Mail: _____