WOODROW SAPP WELL DRILLING, INC.
4774 NEW JESUP HIGHWAY
BRUNSWICK, GA 31520
P (912) 265-2603
F (912) 262-0423
www.woodrowsapp.com

PUMPING TEST REPORT

WELL **12"** PUMP **75 HP TURBINE** DATE **9/23/2021**

FOR **BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION**

CITY **BRUNSWICK** STATE **GA**

LOCATION **CANAL RD WELL (115 HARRY DRIGGERS BLVD)**

GPM **1836**

STATIC WATER LEVEL **3 FT** DRAWDOWN **19 FT**

LENGTH OF AIRLINE _____ MEASURING AIRLINE _____ FT _____ IN

FLOW METER **TRANSIT TIME** WATER TEMPERATURE _____

TIME	AM / PM	WATER LEVEL (ft.)	DRAWDOWN (ft.)	GPM	SPECIFIC CAPACITY
10:00	AM	20	17	1836	108.00
10:15	AM	20	17	1821	107.12
10:30	AM	21	18	1824	101.33
10:45	AM	21	18	1829	101.61
11:00	AM	22	19	1830	96.32
11:30	AM	22	19	1825	96.05
12:00	PM	22	19	1824	96.00
12:30	PM	22	19	1829	96.26
1:00	PM	22	19	1827	96.16
1:30	PM	22	19	1830	96.32
2:00	PM	22	19	1830	96.32