

STATE OF GEORGIA
DEPARTMENT OF NATURAL RESOURCES
ENVIRONMENTAL PROTECTION DIVISION

OWNER: Brunswick - Glynn County Joint Water Sewer Commission

PERMIT NO.: CG1270000

SYSTEM: Brunswick Water System

PERMIT CONDITIONS

4. **This permit is for the operation of a public water system using twelve (12) wells as sources of water supply** as indicated on your application. Any additional sources must have written approval from the Director before use. **The total amount of water produced must not exceed the limits imposed by your groundwater withdrawal permit, #063-0011.** The approved sources of water are:

Well #3, Source 103, Hampton Avenue Goodyear
Well #4, Source 104, Townsend St. Brunswick Villa
Well #8, Source 108, Tucson Drive FLETC
Well #9, Source 109, Transportation Lane FLETC
Well #10, Source 110, Howard Coffin Park
Well #12, Source 112, Glyndale Drive & East Howard
Well #14, Source 114, Glyndale Drive & East Howard
Well #15, Source 115, Perry Lane Road
Well #16, Source 116, Perry Lane Road
Well #17, Source 117, Harry Driggers Blvd.
Well #18, Source 118, Shell Road
Well #19, Source 119, Golden Isles Parkway

5. The permittee must provide continuous disinfection by chlorinating all water distributed by the system to maintain a detectable residual of free chlorine in the recommended amount of 0.2 milligrams per liter in all parts of the distribution system, or as specified in Section 391-3-5-.14, as amended, of the Rules for Safe Drinking Water.

6. **The permittee shall analyze or have analyzed all microbiological and chemical samples required by the Rules for Safe Drinking Water, Chapter 391-3-5. Monitoring for each contaminant must be performed as scheduled by the Georgia Environmental Protection Division's (EPD) Watershed Compliance Program (WCP). The supplier must provide all test results to the WCP within the time frames established in the schedules.** The permittee may use the laboratory services of the EPD's certified laboratory or any other laboratory certified by the WCP to perform the specific analysis. If a laboratory other than the EPD's certified laboratory is used, the laboratory results must be submitted to the following address as specified in Section 391-3-5-.30:

Environmental Protection Division
Watershed Protection Branch Compliance Program
Drinking Water Compliance Unit
2 Martin Luther King, Jr. Drive, SE, Suite 1152 East
Atlanta, Georgia 30334

The format used to report results must be approved by the WCP and must identify the system by the water system identification number, WSID# 1270000, and the laboratory performing the analysis. The laboratory's certification number must be included on the report. Results requiring immediate notification should be reported to the WCP by telephone at (404) 463-1511 or fax at (404) 651-9590.