



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

September 23, 2022

**PROJECT: INVITATION FOR BID NO. 23-008 ELEVATED STORAGE TANK
REHABILITATION FOR GLYNN PLACE MALL &
OGLETHORPE LOCATIONS**

ADDENDUM: Two (2)

DUE DATE: Tuesday, October 4, 2022 12:00PM, NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING
QUESTIONS:**

**1) QUESTION: Please confirm that seed and straw of site will be acceptable site
restoration for this project.**

**ANSWER: Seed and straw will NOT be accepted for final site restoration. As noted
in Technical Spec Section 2.14 – The Contractor shall level area with bank sand so
that new grass surfaces match the level of existing grass and maintain pre-
construction drainage patterns. Level and fill minor ruts or depressions caused by
construction operations with bank sand, where the grass is still viable. Contractor
shall also restore unpaved areas not requiring sodding with hydro-mulch seeding
and fertilizer accordingly.**

**2) QUESTION: Who will be responsible for pulling water samples and paying for Bac-
T?**

**ANSWER: The JWSC will be responsible for pulling water samples and paying for
the Bac-T testing.**

- 3) **QUESTION:** Addendum #1 states that there are drawings available for the Oglethorpe tank. Can you please provide a copy?

ANSWER: Please use the following Dropbox link to access the drawings for the Oglethorpe tank,

[https://www.dropbox.com/s/49o79zdzg4kx0ej/Oglethorpe%20Park%20EST%20Re
cord%20Drawings%2005-2005.pdf?dl=0](https://www.dropbox.com/s/49o79zdzg4kx0ej/Oglethorpe%20Park%20EST%20Record%20Drawings%2005-2005.pdf?dl=0)

- 4) **QUESTION:** Will there be additional addendums issued for this project.

ANSWER: There is the possibility of additional addendums being issued for questions sent before the 5:00PM deadline.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: TWO (2)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title