



## **BRUNSWICK-GLYNN JOINT WATER & SEWER COMMISSION**

**March 17, 2023**

**PROJECT:** Request for Proposal No. 23-018 Engineering Services for SPLOST Exit 29 Water Production Facility & Elevated Storage Tank

**ADDENDUM:** One (1)

**DUE DATE:** Tuesday, March 28, 2022 – 12:00 P.M., EST

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING QUESTIONS:**

- 1) QUESTION:** What is the anticipated design flow rate? What is the anticipated future flow rate?

**ANSWER:** According to pump records, the pump was designed to produce 1500 GPM at 160 TDH. The anticipated future rate is undetermined.

- 2) QUESTION:** Is there water quality data available from the well? If so, can this data be provided? Has saltwater intrusion been seen or is saltwater intrusion anticipated for this well?

**ANSWER:** The water quality data available for this well has been posted to the solicitation website, <https://www.bgjwsc.org/request-for-proposal-no-23-018-engineering-services-for-splost-exit-29-water-production-facility-elevated-storage-tank/>.

- 3) QUESTION:** Can BGJWSC provide any drawings or information on the existing infrastructure in the area?

**ANSWER:** Available drawings have been posted to the solicitation website, <https://www.bgjwsc.org/request-for-proposal-no-23-018-engineering-services-for-splost-exit-29-water-production-facility-elevated-storage-tank/>.

**4) QUESTION:** Which aquifer provides water to the existing well?

**ANSWER:** The Upper Floridan aquifer provides water to the existing well.

**5) QUESTION:** Are firms allowed to include resumes in a separate appendix or are they part of the three page limit?

**ANSWER:** Yes, resumes are covered in the page count. Required BGJWSC forms such as Oath and Affidavit are not part of the page count.

**6) QUESTION:** How many copies of the proposal should be provided?

**ANSWER:** Your proposal should contain one (1) original, four (4) copies, and one (1) electronic copy (USB or CD).



**All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.**

**ACKNOWLEDGEMENT  
ADDENDUM: ONE (1)**

**DATE:** \_\_\_\_\_

**The above Addendum is hereby acknowledged:**

\_\_\_\_\_  
**(NAME OF BIDDER)**

\_\_\_\_\_  
**Signature**

\_\_\_\_\_  
**Title**