



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

June 16, 2023

PROJECT: INVITATION FOR BID NO. 23-021 Pump Station 4044
Rehabilitation

ADDENDUM: One (1)

DUE DATE: Tuesday, July 11, 2023 12:00PM, NOON

THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING QUESTIONS:

- 1) **QUESTION:** What is the diameter and depth of the structure to be converted to a manhole? What is the condition of the structure currently? Is it partially or fully deteriorated?

ANSWER: The existing PS 4044 wetwell that will be converted to a receiving manhole is 6 feet in diameter and +/- 23 feet deep. The private lift station wetwell that will be converted to a manhole is 4' in diameter and +/-13.5 feet deep. As stated in the instructions to bidders, "the Bidder is encouraged to examine the location of the work and inform himself fully as to the conditions present at the site" and on the bid form "the BIDDER declares that he has examined the site of the work and informed himself fully in regard to all conditions pertaining to the place where the work is to be done."

- 2) **QUESTION:** Substitution question, how would Spraywall be evaluated for potential inclusion in the specification for this project versus the calcium aluminate that is currently specified? The materials are quite different in nature.

ANSWER: All lining materials must meet current BGJWSC and project specifications. Polyurethane is not an acceptable substitute for calcium aluminate.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: ONE (1)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title