

BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

July 27, 2023

PROJECT: INVITATION TO BID NO. 23-011 NORTH MAINLAND WATER

LOOPS CONSTRUCTION

ADDENDUM: Three (3)

DUE DATE: TUESDAY, AUGUST 8, 2023 – 12:00PM, NOON EST

THIS ADDENDUM IS FOR THE PURPOSE OF MAKING THE FOLLOWING CHANGES AND CLARIFICATIONS:

1) QUESTION: Bid Item #14 is for 24" OD HDPE horizontal directional drilling, but we do not see that called out on the plans. The three locations of horizontal directional drilling shown on the plans is covered by bid items 12 and 13. Please confirm that bid item 14 is an error and will be removed.

ANSWER: The 24" OD HDPE horizontal directional drilling (bid item #14) is for a casting pipe under Golden Isles Parkway (Project Area #3), in which the 10" OD pipe will be a carrier pipe that is inserted into the larger pipe. This is described within Section 01010 "Summary of Work" on the specifications. A revised drawing will be provided to further clarify this scope of work.



All applicants under this Invitation for Bid are kindly requested to acknowledge receipt of this Addendum in original only.

ACKNOWLEDGEMENT ADDENDUM: THREE (3)

| | DATE: | |
|----------------------|-------------------------|--|
| The above Addendum i | is hereby acknowledged: | |
| | | |
| | | |
| | (NAME OF BIDDER) | |
| | | |
| Signature | | |

