



- CONNECTION NOTES:**
1. INSPECT AND CLEAN EXISTING OR PLUG PER JWSC 2.5.3.8.
 2. REMOVE ANY CAPS OR PLUGS.
 3. TEST EXISTING STUB OUT AT 150 PSI AT 2 HOUR HYDROSTATIC TEST. PSI TEST PRIOR TO ANY CONNECTION. DO NOT AIR TEST ANY PIPES.
 4. CONNECT TO EXISTING STUB WITH PROPOSED WATERMAIN PIPE.
 5. SECURE NEW PIPE TO STUB WITH MECHANICAL JOINT.
 6. CONNECTION TO BE PERFORMED AT NIGHT.



THIS ITEM HAS BEEN DIGITALLY SIGNED AND SEALED BY DWAYNE R. FALLS, PE ON THE DATE ADJACENT TO THE SEAL. PRINTED COPIES OF THIS DOCUMENT ARE NOT CONSIDERED SIGNED AND SEALED AND THE SIGNATURE MUST BE VERIFIED ON ANY ELECTRONIC COPIES.

REV	NO	DATE	DESCRIPTION
1	1	7/27/23	TSS DRF CASING PIPE
2	2	7/27/23	TSS DRF CASING PIPE
3	3		
4	4		
5	5		
6	6		
7	7		

AREA 3 PROPOSED IMPROVEMENTS

BRUNSWICK-GLYNN JWSC
NORTH MAIN AND WATER LOOPS PROJECT

BGJWSC
GLYNN COUNTY, GEORGIA

DESIGN	ISSUE	DATE	ISSUE
DRF	TSS	21-1028	
JOB#	ISSUE	MAY 2023	
	ISSUE		IFB

FOUR WATERS ENGINEERING

324 6th AVE N. JACKSONVILLE BEACH, FLORIDA 32250
844-414-2400 GALIC# PEF006711 WWW.4WENG.COM

DRAWING NUMBER
C-12