#2105 PUMPSTATION 4044 REHAB (1%-OCTOBER 2024)





- 1. View of the existing Prime South Bank private pump station to be converted into a receiving MH.
- 2. View of the existing Pump Station 4044 wet well to be rehabbed to provide additional storage in the system Contractor to removed valve vault and control panels, replace the existing top w/ a new top with 30-inch composite ring and cover and safety grate. And coat the entire wet well.