



BRUNSWICK-GLYNN COUNTY JOINT WATER & SEWER COMMISSION

October 23, 2026

**PROJECT: REQUEST FOR PROPOSAL NO. 27-006 CONSTRUCTION
SERVICES FOR BASIN 4001 AND 4013 CIPP**

ADDENDUM: FOUR (4)

DUE DATE: TUESDAY, NOVEMBER 10, 2026 – 12:00PM, NOON

**THIS ADDENDUM IS FOR THE PURPOSE OF ANSWERING THE FOLLOWING
QUESTIONS:**

- 1) QUESTION: Can the JWSC please provide a table of manhole depths per segment for CIPP thickness calculations?**

ANSWER: This information is not available

- 2) QUESTION: Is steam curing an acceptable method of curing CIPP liners?**

ANSWER: No, this will not be allowed for this project

- 3) QUESTION: Do firms need to send pre-approval documentation?**

ANSWER: No, JWSC does not have a pre-approval process for this project.

- 4) QUESTION: The Pre-Qualifications paragraph in each section (Section 01000, PDF page 118; Section 02000, PDF page 137) requires “an onsite field supervisor with the required years of experience, plus a minimum of two references that can be used to verify this experience”, as well as 5 similar projects with cleaning and inspection equipment as proposed for this project”. The Required Bid Submittals list in Section V of the ITB (PDF page 11) does not include these items and no form is provided for them. Please confirm if the 2 supervisor references are required with the bid submittal; are the 5 similar projects required with the bid submittal, or only from the successful bidder after award; if either is required with the bid, may it be provided on a separate sheet in the bidder’s own format?**

ANSWER: Yes, the two supervisor references are required with the bid submittal; Yes, the five similar projects are required at the time of bid submittal; Yes, these items may be submitted in the bidder's own format.



All applicants under this Request for Proposal are kindly requested to acknowledge receipt of this Addendum in original only.

**ACKNOWLEDGEMENT
ADDENDUM: FOUR (4)**

DATE: _____

The above Addendum is hereby acknowledged:

(NAME OF BIDDER)

Signature

Title